

CERTIFICATE OF CONFORMITY

1. HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

2. **Certificate No:** FM21CA0090X

3. **Equipment:** 645i, 745i and TM500 Series Thermal Mass Flow Meter and Temperature Transmitter
(Type Reference and Name)

4. **Name of Listing Company:** Sierra Instruments Inc

5. **Address of Listing Company:** 5 Harris Court,
Monterey, California 93940, USA

6. The examination and test results are recorded in confidential report number:

PR461840 dated 17th May 2022

7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

CSA C22.2 No. 0.4:2017 (R2022), CSA C22.2 No. 0.5:2016 (R2020), CSA C22.2 No. 25:R2014,
CSA C22.2 No. 30:R2016, CSA C22.2 No. 94:1991 (R2011), CSA C22.2 No. 60079-0:2019,
CSA C22.2 No. 60079-1:2016, CSA C22.2 No. 60529:2016, CSA C22.2 No. 61010-1:2012

8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.

9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

10. Equipment Ratings:

Explosionproof for Class I, Division 1, Groups B, C and D; Dust-ignitionproof for Class II, Division 1, Groups E, F and G; Class III, Division 1; Flameproof for Class I, Zone 1, Ex db IIB+H2 T6 or T4 Gb hazardous locations, indoors and outdoors (Type 4X, IP67) with an ambient temperature rating of -40°C to +70°C (-20°C for Zones).

Certificate issued by:



J.E. Marquedant
VP, Manager - Electrical Systems

18 September 2023

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 348 (Apr 21)



SCHEDULE

Canadian Certificate Of Conformity No: FM21CA0090X



11. The marking of the equipment shall include:

Main Enclosure:

Class I Division 1, Groups B, C, D; T6 or T4 Ta = -40°C to +70°C; Type 4X, IP67

Class II, Division 1, Groups E, F, G, Class III, Division 1; T6 or T4 Ta = -40°C to +70°C; Type 4X, IP67

Class I, Zone 1, Ex db IIB+H2 T6 or T4 Gb Ta = -20°C to +70°C, Type 4X, IP67

Remote Enclosure:

Class I Division 1, Groups B, C, D; T4 Ta = -40°C to +70°C; Type 4X, IP67

Class II, Division 1, Groups E, F, G, Class III, Division 1; T4 Ta = -40°C to +70°C; Type 4X, IP67

Class I, Zone 1, Ex db IIB+H2 T4 Gb Ta = -20°C to +70°C, Type 4X, IP67

12. Description of Equipment:

General - The 645i, 745i and TM500 Series Thermal Mass Flow Meter and Temperature Transmitters are used for measuring the mass flow of gases as well as the process gas temperature all in one package. The flowmeters are available for inline or insertion applications. The product features 4-20mA and/or pulse outputs and is also available with an optional display/configuration panel. Digital communications options include USB, HART and RS485 Modbus.

Construction - The 645i, 745i and TM500 Series Thermal Mass Flow Meter and Temperature Transmitter consists of a dual-compartment electronics housing with thread-on blank or window covers and a probe threaded into the housing base. The remote version of the 645i, 745i and TM500 Series Thermal Mass Flow Meter and Temperature Transmitter consists of the same dual-compartment electronics housing attached to a smaller remote enclosure with probe. The enclosures are provided with 3/4 inch NPT openings. Probe mounting can be provided integrally, directly to the electronics housing, or can be remotely mounted, using the remote enclosure, up to 100 feet from the electronics housing.

Ratings - The 645i, 745i and TM500 Series Thermal Mass Flow Meter and Temperature Transmitters operate at 12-28 Vdc (6W) or 100-240 Vac (7W). The transmitters are rated for use in an ambient temperature range of -40°C to +70°C for Divisions or -20°C to +70°C for Zones. The transmitter probes are rated for use in a process temperature range of -40°C to +121°C at a maximum pressure of 740 psi.

See Annex for model codes.

13. Specific Conditions of Use:

1. The flamepaths of the equipment are not intended to be repaired. Consult the manufacturer if repair of the flamepath joints is necessary.
2. Refer to the manufacturer's instructions to reduce the potential of an electrostatic charging hazard on the equipment enclosure.
3. The equipment temperature code ratings are dependent on the enclosure configuration (local or remote). Refer to the following table for specific temperature code markings.

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 348 (Apr 21)



Page 2 of 4

SCHEDULE

Canadian Certificate Of Conformity No: FM21CA0090X



Member of the FM Global Group

Model Code	Temperature Code Marking	
	Main Enclosure	Remote Enclosure
E1	T4	N/A
E2	T4	N/A
E3	T6	T4
E4	T6	T4

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
17 May 2022	Original Issue.
18 September 2023	<u>Supplement 1:</u> Report Reference: PR466793 dated 18 September 2023. Description of the Change(s): Minor model code changes and associated documentation changes. Standards updated to latest editions or reaffirmed dates where changes between versions are considered non-technical.

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 348 (Apr 21)



SCHEDULE

Canadian Certificate Of Conformity No: FM21CA0090X



ANNEX

645i Series and TM500 Series Insertion

Description of Equipment:

a-b-c-d-e. Thermal Mass Flow Meter and Temperature Transmitter (Insertion).

a = Model 645i or TM500.

b = Probe 04I, 05I, 06I, 07I, 08I, 09I, 10I, 11I, 12I, 13I, 14I, 15I, 16I, 17I, 18I, 19I, 20I, 21I, 22I, 23I, 24I, 25I, 26I, 27I, 28I, 29I, 30I, 31I, 32I, 33I, 34I, 35I, 36I, 15R, 18R, 24R, 30R or 36R.

c = Enclosure E1, E2, E3 or E4.

d = Communication BH, BN, B0 or RS.

e = Data logger, display and sensor BLANK, DL, D0, LD0, SH, SJ or SI.

745i Series and TM500 Series Inline

Description of Equipment:

a-b-c-d-e. Thermal Mass Flow Meter and Temperature Transmitter (Inline).

a = Model 745i or TM500.

b = Flow body 05F, 075F, 10F, 15F, 20F, 25F, 30F, 40F, 60F, 125F, 20FC, 25FC, 30FC, 40FC, 60FC, 075G, 10G, 15G, 20G, 25G, 30G, 40G, 60G, 125G, 20GC, 25GC, 30GC, 40GC, 60GC, 025P, 05P, 075P, 10P, 15P, 20P, 25P, 30P, 40P, 125P, 20PC, 25PC, 30PC or 40PC.

c = Enclosure E1, E2, E3 or E4.

d = Communication BH, BN, B0 or RS.

e = Data logger, display and sensor BLANK, DL, D0, LD0, SH, SJ or SI.

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 348 (Apr 21)

